

ADDENDUM NO. 2

APRIL 19, 2017

RE: COLVILLE AIRPORT TRANSMISSION MAIN

OWNER: CITY OF COLVILLE

FROM: Welch, Comer & Associates, Inc.
350 E. Kathleen Ave.
Coeur d'Alene, Idaho 83815
Phone: (208) 664-9382 Fax: (208) 664-5946

TO: ALL PLAN HOLDERS

The following modifications, clarifications and information are hereby made a part of the contract provisions and shall be fully binding.

This Addendum consists of **1** Addendum page.

IMPORTANT: Bidders must acknowledge receipt of this Addendum as well as all other issued addenda on the Bid Form provided with the Contract Documents, which must be utilized by Bidder for bid to be considered responsive. Failure to do so may subject Bidder to disqualification.

CLARIFICATION:

1. With reference to **Section 33 1116, Paragraph 3.12 Testing:**

- There shall be no direct connection without approved backflow device between any new water line and the existing city water system performed until all sterilization, flushing, bacteriological testing, and hydrostatic pressure testing have been completed to the satisfaction of the City. (It is noted that the City has a 4" backflow prevention device that may be utilized by the Contractor to complete testing, upon request.)
- Contractor shall be responsible for all temporary valving, fitting, thrust blocks, and other material required to complete pressure test as well as disinfection per Section 33 1300.

2. With reference to **Section 33 1300:**

- Flushing of the new 12" waterline can be routed to the overflow swale/storm drain south of the new Reservoir 3. Contractor shall coordinate with City and Engineer prior to flushing.
- Flushing of the new 16" waterline can be routed to the new Reservoir 3. Contractor shall coordinate with the City and Engineer prior to flushing.

END OF ADDENDUM 2