

ADDENDUM NO. 2

OCTOBER 12, 2017

RE: FLORIDA LANE RESERVOIR ROOF STRUCTURE

OWNER: SPOKANE COUNTY WATER DISTRICT NO. 3

FROM: Welch, Comer & Associates, Inc.
350 E. Kathleen Ave.
Coeur d'Alene, Idaho 83815
Phone: (208) 664-9382 Fax: (208) 664-5946

TO: ALL PLAN HOLDERS

The following modifications, clarifications and information are hereby made a part of the contract provisions and shall be fully binding.

This Addendum consists of **1** Addendum page.

IMPORTANT: Bidders must acknowledge receipt of this Addendum as well as all other issued addenda on the Bid Form provided with the Contract Documents, which must be utilized by Bidder for bid to be considered responsive. Failure to do so may subject Bidder to disqualification.

DRAWINGS:

With reference to **Sheet A2**, existing concrete reservoir generally slopes from West to East, dropping 1.5 feet over 75 feet.

With reference to **Sheet A2**, existing concrete reservoir slab is 8-inches thick, minimum. Internal column thickness is approximately 14-inches.

CLARIFICATION:

1. Existing concrete reservoir generally slopes from West to East. Roof structure and columns shall fit according to location along the sloped concrete surface.
2. With reference to **Sheet S0**, wind load calculations have been performed. The Contractor is responsible for ensuring that the standing seam roof can withstand the pressures provided.
3. With reference to **Special Provisions, Section 1-07.6 Permits and Licenses**, Contractor is responsible for all required permits for this project.

END OF ADDENDUM 2