

ADDENDUM NO. 1

FEBRUARY 8, 2018

RE: GREENSFERRY LIFT STATION PROJECT

OWNER: CITY OF RATHDRUM

FROM: Welch, Comer & Associates, Inc.
350 E. Kathleen Ave.
Coeur d'Alene, Idaho 83815
Phone: (208) 664-9382 Fax: (208) 664-5946

TO: ALL PLAN HOLDERS

The following modifications, clarifications and information are hereby made a part of the contract provisions and shall be fully binding.

This Addendum consists of **2** Addendum pages.

IMPORTANT: Bidders must acknowledge receipt of this Addendum as well as all other issued addenda on the Bid Form provided with the Contract Documents, which must be utilized by Bidder for bid to be considered responsive. Failure to do so may subject Bidder to disqualification.

TECHNICAL SPECIFICATIONS:

With reference to **Section 01 3100, Paragraph 1.04.D.2.b.i**, replace with the following:

- i. Within 30 days of receipt of approval, submit three (3) paper copies AND three (3) electronic copies on Compact Disc (CD-ROM) in Portable Document Format (PDF).

With reference to **Section 05 1200, Paragraph 2.01.A.1**, replace with the following:

1. Model: LHH ½

With reference to **Section 05 1200, Paragraph 2.01.B.1**, replace with the following:

1. Model: CBTP-0050

With reference to **Section 31 2316, Paragraph 1.05**, delete in its entirety.

With reference to **Section 31 2323, Paragraph 1.02.A**, delete in its entirety.

CLARIFICATION:

1. With reference to Sheet P1, Bypass Manhole to have a total depth of 8 ft. with an open bottom.
2. With reference to Sheet P2, 5 ft. diameter manhole to have an invert elevation of 2156.8 and rim elevation of 2172.0.
3. The following are approved for substitution for the lighting schedule:
 - a. F1 – ILP WTZ-44WLED-UNIV-40DPCL
 - b. F2 – Visionaire VSX-1-16LC-7-4k-UNV-WM-BZ-PCRXXX
 - c. F4 – Visionaire VSX-1-16LC-7-4K-UNV-WM-BZ
 - d. F5 – Visioneering LSVA48-LED840K-058LUNV-M10(XX)XH

END OF ADDENDUM 1