

# ADDENDUM NO. 3

For the Bid of

## AVONDALE / PT. HAYDEN WATERLINE PROJECT

North Kootenai Water District

April 13, 2010

**FROM:** Welch, Comer & Associates, Inc.  
350 E. Kathleen Avenue  
Coeur d'Alene, ID 83815 Phone: (208) 664-9382, Fax: (208) 664-5946

**TO:** ALL PLAN HOLDERS

This Addendum consists of **2** page(s).

**IMPORTANT:** Bidders must acknowledge receipt of this Addendum as well as all other issued addenda on the Bid Form provided with the Contract Documents, which must be utilized by Bidder for bid to be considered responsive. Failure to do so may subject Bidder to disqualification.

**PLEASE NOTE:** Due to the time frame to the bid opening in which this addendum is being issued, faxed acknowledgements of Addendum No. 3 will be accepted. Please fax your acknowledgement to the District office at (208) 762-0355 prior to 2:00 pm (PDT) April 14, 2010. All other addenda must be acknowledged on the Bid Form.

### **PART 3 – TECHNICAL SPECIFICATIONS:**

**With reference to Section 33 1116 Site Water Utility Distribution Piping, Paragraph 1.03.W.2, add the following:**

All labor, material and equipment necessary to furnish and install pipe bedding shall be considered incidental to this pay item.

**With reference to Section 33 1116 Site Water Utility Distribution Piping, Paragraph 1.03, add the following:**

AN. Clay Plugs:

1. Measurement Method: Shall be considered incidental to other items of the work.
2. Includes: All labor, material and equipment necessary to install clay plugs as specified and as detailed in the drawings, or as directed in the field by the Engineer.

**With reference to Section 33 4111 Site Storm Utility Drainage Piping, Paragraph 1.03.C.2, delete the following:**

Removal and disposal of existing culvert shall be considered incidental to this item.

**With reference to Section 33 4111 Site Storm Utility Drainage Piping**, Paragraph 1.03.D, add the following:

3. Excludes: Payment shall not be made for labor, material and equipment necessary to furnish and install new culvert where careless construction practices have resulted in damage to the existing culvert.

**GENERAL CLARIFICATIONS:**

1. Further clarification with respect to Addendum No. 2, Answer 6 to the questions asked at the pre-bid meeting:

Contractor shall NOT be responsible for providing Owner-approved backflow prevention device. Owner will provide a backflow prevention device for Contractor's use. Contractor shall return the device in good working order. Any damage that occurs to the device during construction shall be repaired at the Contractor's expense. Contractor shall be responsible to pay Owner for construction water used from the approved hydrant as metered on a monthly basis using the following rate schedule:

- \$1.10 per 1,000 gallons for the first 5,000 gallons used each month
- \$1.27 per 1,000 gallons for 5,001 to 15,000 gallons used each month
- \$1.44 per 1,000 gallons for 15,001 to 30,000 gallons used each month
- \$2.19 per 1,000 gallons for 30,001 and over gallons used each month

2. Paragraph 2.01.G applies to temporary services and temporary main as well as to service lines.
3. **With reference to Detail 1/WD13**, the asphalt path and associated aggregate base material will be paid under Pay Item 32 1216.06 Asphalt Driveway or Path and the area outside the asphalt path (up to an 8-foot pay limit centered on the waterline trench) will be paid under Pay Item 32 9219.04 Golf Course Restoration.
4. **With reference to Section 33 1116 Site Water Utility Distribution Piping**, Paragraph 3.07.Q (refer to Addendum No. 2), the definition of "very moist soil conditions" is as follows:

Locations where groundwater is present within the water main trench excavation (at any depth) or within the excavation(s) for the service bore installation.

**END OF ADDENDUM 3**