

ADDENDUM NO. 1

For the Bid of

ST. MARIES WATER TREATMENT PLANT CORROSION CONTROL IMPROVEMENTS PROJECT

City of St. Maries, Idaho

July 27, 2010

FROM: Welch, Comer & Associates, Inc.
350 E. Kathleen Avenue
Coeur d'Alene, ID 83815 Phone: (208) 664-9382, Fax: (208) 664-5946

TO: ALL PLAN HOLDERS

This Addendum consists of **1** page(s).

IMPORTANT: Bidders must acknowledge receipt of this Addendum as well as all other issued addenda on the Bid Form provided with the Contract Documents, which must be utilized by Bidder for bid to be considered responsive. Failure to do so may subject Bidder to disqualification.

July 22 Pre-Bid Walk Through Clarifications:

1. The Owner will provide power to the equipment locations for the soda ash mixing and metering equipment.
2. The Contractor may take down the exterior fencing for access but must restore it to original condition.
3. The existing hot water tank may remain in its current location.
4. With reference to Sheet DT1: Change the two ½" PEX solution lines to ¾" as shown on Sheet DT2.
5. Change the contract times to one hundred eighty (180) calendar days to substantial completion. This is to allow for lead time for equipment supply.
6. Add a milestone that exterior work must be completed within thirty (30) calendar days of award.

END ADDENDUM NO. 1